



NOTES:

1. ALL WIRE NUMBERING TO BE AS PER THIS DRAWING. THIS INCLUDES ALL TELEMETRY WIRING.
2. CONTRACTOR TO CONFIRM EQUIPMENT RATINGS PRIOR TO CONSTRUCTION AND SELECT SWITCHGEAR, CONTROL GEAR AND CABLE RATINGS TO SUIT FINAL EQUIPMENT.
3. ALL CIRCUIT BREAKERS ARE TO BE "D CURVE" UNLESS OTHERWISE NOTED.
4. HYGROSTAT 24-230V AC/DC, 30W.
5. ALL WIRING TO BE COLOUR CODED

AS FOLLOWS:

RED - 240V AC ACTIVE
 ORANGE - 240V AC CONTROL
 BLACK - 240V AC NEUTRAL
 PINK - 24V AC ACTIVE
 GREY - 24V AC CONTROL
 BROWN - 24V AC NEUTRAL
 RED WITH WHITE TRACE - 24V DC POSITIVE
 PURPLE - 12V DC POSITIVE
 BLACK WITH WHITE TRACE - 0V DC
 GREEN/YELLOW - EARTH