



NOTES:

1. ALL WIRE NUMBERING TO BE AS PER THIS DRAWING. THIS INCLUDES ALL TELEMETRY WIRING.

2. CONTRACTOR TO CONFIRM EQUIPMENT RATINGS PRIOR TO CONSTRUCTION AND SELECT SWITCHGEAR, CONTROL GEAR AND CABLE RATINGS TO SUIT FINAL EQUIPMENT.

3. ALL CIRCUIT BREAKERS ARE TO BE "D CURVE" UNLESS OTHERWISE NOTED.

4. HYGROSTAT 24-230V AC/DC
30W.

5. ALL WIRING TO BE COLOUR CODED

- AS FOLLOWS:

- RED - 240V AC ACTIVE
ORANGE - 240V AC
CONTROL
BLACK - 240V AC NEUTRAL
PINK - 24V AC ACTIVE
GREY - 24V AC CONTROL
BROWN - 24V AC NEUTRAL
RED WITH WHITE TRACE -
24V DC POSITIVE
PURPLE - 12V DC POSITIVE
BLACK WITH WHITE TRACE
- 0V DC
GREEN/YELLOW - EARTH

[illegible]