



## Water Quality Monthly Results

**DATE:** April 2015

**RE:** Corinella Locality (incorporating Corinella, Coronet Bay and Tenby Point)

| Parameter               | Units      | Number of Samples | Monthly Result | Quality standard |
|-------------------------|------------|-------------------|----------------|------------------|
| <i>Escherichia coli</i> | orgs/100mL | 4                 | 0              | 0                |
| Turbidity               | NTU        | 4                 | 0.2            | <5               |
| Trihalomethanes         | mg/L       | 1                 | 0.087          | <0.25            |
| Aluminium               | mg/L       | 1                 | 0.01           | <0.2             |
| Chloroacetic acid       | mg/L       | 1                 | <0.005         | <0.15            |
| Dichloroacetic acid     | mg/L       | 1                 | <0.005         | <0.1             |
| Trichloroacetic acid    | mg/L       | 1                 | <0.005         | <0.1             |

For further information regarding the quality standards for parameters please go to Westernport Water's Water Quality webpage

Regards,

Jake Weir  
**WATER QUALITY OFFICER**