



Water Quality Monthly Results

DATE: December 2014

RE: Grantville Locality (incorporating Grantville, Deep Creek Estate and Pioneer Bay)

Parameter	Units	Number of Samples	Monthly Result	Quality standard
<i>Escherichia coli</i>	orgs/100mL	5	0	0
Turbidity	NTU	5	0.2	<5
Trihalomethanes	mg/L	1	0.12	<0.25
Aluminium	mg/L	1	0.01	<0.2
Chloroacetic acid	mg/L	1	<0.005	<0.15
Dichloroacetic acid	mg/L	1	0.015	<0.1
Trichloroacetic acid	mg/L	1	0.007	<0.1

For further information regarding the quality standards for parameters please go to Westernport Water's Water Quality webpage

Regards,

Jake Weir
WATER QUALITY OFFICER